


The Topog-E Gasket Company

Installation of Topog-E® gaskets in steam boilers






3. Gaskets on the bottom of a boiler shell are typically more difficult to install without leaking because small particles tend to become lodged between the mating surfaces after they have been cleaned. This can lead to over-tightening of the gasket to stop leakage. It is recommended to drain the boiler and start over or the gasket's service life may be shortened.



4. Do not over-tighten as it will over-compress the gasket and shorten its service life.

If gasket leaks while pressure is being built up, tighten only enough to stop leakage.





- 6. Never re-use a Topog-E® gasket!
- Topog-E[®] bolt gaskets (when required) should be used with Topog-E[®] handhole gaskets.

Topog-E® gaskets are sold for use in steam, water, air, and other selected applications only. Recommendations for their use are based on tests believed to be reliable and on actual customer experience. Since their installation and use are beyond our control we cannot guarantee the results, whether or not such use is in accordance with instructions. We disclaim any responsibility.

© Copyright 2004 Topog-E® Gasket Company